



We help ideas meet the real world

Compliance Statement

No. 2016-561

Screened Channel, Class E_A

Company

Sterling
3 The Business Centre
Molly Millars Lane,
Wokingham, Berks
RG41 2EY, UK

Channel Identification (4 connector model)

Horizontal cable:

Sterling Cat6a U/FTP 23awg horizontal cable LSZH. Part no. 951015

Telecommunication outlet, patch panel, and CP jacks:

Sterling Cat6a tool-less keystone jack. Part no. KS-J-C6ASTP

Equipment cord and CP cord:

Sterling Cat6a U/FTP solid cable LSZH lead. Part no. C6A-PCS-xx-x (x: length and colour)
(with jack KS-J-C6ASTP added)

Terminal cord and patch cord:

Sterling Cat6a S/FTP patch leads LSZH. Part no. C6A-PC-xx-x (x: length and colour)

Generic cabling standards - Class E_A Channel requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- EN 50173-1:2011
- EN 50173-2:2007, including amendment A1:2010
- ANSI/TIA-568-C.2:2009

Technical report

DELTA-T213173-02, DANAK-19/16910

EC Cabling product ID


6081

CS valid until

7 December 2017

This product has been tested by DELTA EC Cabling Group and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 7 October 2016


Lars Lindskov Pedersen
Test Manager


Claude Videt
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.madebydelta.com/cable

